



Louisa County Water Authority

2022 Annual Drinking Water Quality Report for the Zion Crossroads System

We are pleased to present to you this year's Annual Drinking Water Quality Report which is designed to inform you about the quality water services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process, protect our water sources, and ensure the quality of your water. Our water source is a ground water system from a series of wells located in the Green Springs and Zion Crossroads areas of Louisa County. Sodium Hypochlorite is added to disinfect the water prior to distribution.

A source water assessment for Louisa County Water Authority was completed by the Virginia Department of Health on October 3, 2002. This assessment determined that the raw water sources (Zion Crossroads Well 1 & 2 Green Springs Wells 1, 2 & 3) may be highly susceptible to contamination. A source water assessment has not been completed for Spring Creek Well 3.

This report shows our water quality and what it means. If you have any questions about this report, please contact Pam Baughman, General Manager. If you want to learn more about the water treatment process, please attend any of our regularly scheduled Board of Director meetings. They are held on the second Wednesday of every month at 6:00 p.m. at the County Administration Building, first floor meeting room, 1 Woolfolk Avenue, Louisa, Virginia 23093. If you require further information, please call our business office at 540-967-1122 during our regular office hours of 8:00 a.m. - 4:30 p.m. Monday – Friday.

Louisa County Water Authority routinely monitors for constituents in your drinking water according to Federal and State laws. The following tables show the highest results of our monitoring for each constituent and testing for the period of January 1 to December 31, 2022. Drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

- Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

To ensure that tap water is safe to drink, EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

In this table you may find some terms and abbreviations with which you might not be familiar. To help you better understand these terms we've provided the following definitions:

Term	Unit Description	Definition
Parts per million (ppm)		Or milligrams per liter (mg/L) – one part per million corresponds to one minute in two years or a single penny in \$10,000.
Parts per billion (ppb)		Or micrograms per liter (µg/L) – one part per billion corresponds to one minute in 2,000 years or a single penny in \$10,000,000
Picocuries per liter (pCi/L)		Aa measure of radioactivity in water.
Nephelometric Turbidity Units (NTU)		A measure of clarity of water. Turbidity more than 5 NTU is just noticeable to the average person.

Beta Emitters	0	50*	6.2*	2.8 – 6.2	pCi/L	No No	2019 2022	Decay of natural deposits. (*The MCL for Beta Emitters is 4 mrem/year (millirems per year) EPA considers 50 pCi/l to be the level of concern for Beta Emitters.)
Combined Radium	0	5	3.8*	2.7 – 3.8	pCi/L	No No	2019 2022	Erosion of natural deposits.
Alpha Emitters	0	15	4.9*	2.6 – 4.9	pCi/L	No No	2019 2022	Erosion of natural deposits.

*Compliance with the MCL's for radiological contaminants is based on an average of 4 consecutive quarterly sample results.

Contaminant	MCLG	MCL	Level Found	Range	Unit Measurement	Violation	Date of Sample	Typical Source of Contamination
Metals								
Sodium			16.3	13.6 – 16.3	ppm	No No	2020 2022	Road salt, septic effluent, animal waste and agrichemicals.

TEST RESULTS: Zion Crossroads Water Distribution System:

Contaminant	MCLG	MCL	Level Found	Range	Unit Measurement	Violation	Date of Sample	Typical Source of Contamination
Total Trihalomethanes	0	80	0.0177		ppb	No	2022	Byproduct of drinking water chlorination.
Highest Compliance Level: 6								
Total Haloacetic Acid	0	60	0.0015		ppm	No	2022	Byproduct of drinking water chlorination.
Highest Compliance Level: 0								

Chlorine Residual Data: Zion Crossroads Water System:

Disinfectant	MRDLG	MRDL	Level Found	Range	Unit Measurement	Violation	Date of Sample (s)	Typical Source
Chlorine	4	4.0	0.79	0.44 - 1.12	mg/L	No	2022	Water additive used to control microbes.

Lead and Copper Water Quality Table: Zion Crossroads Water System (Most Recent Monitoring Period):

Contaminant	MCLG	Action Level	Level Found	Unit Measurement	AL Exceeded	Samples > AL	Date of Sample (s)	Typical Source of Contamination
Lead	0	15	3	ppb	No	1	2020	Corrosion of household plumbing systems; erosion of natural deposits.
Copper	1.3	1.3	26	ppb	No	0	2020	Corrosion of household plumbing systems; erosion of natural deposits.

Normal / Reduced Number of Sample Taps: 20 / 10

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Louisa County Water Authority is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Microbiological Water Quality Table: Zion Crossroads System:

Contaminant	MCLG	MCL	Level Found	Unit Measurement	Violation	Date of Sample	Typical Source of Contamination
<i>E.coli</i> bacteria	0	A routine sample and repeat sample are total coliform positive and one is also <i>E.coli</i> positive	0	Presence or Absence (PA)	No	2022, monthly	Human and animal fecal waste

There were no positive coliform or *E.coli* tests, excessive MCL results, improper treatment techniques, or monitoring and reporting violations during 2022.

Thank you for allowing us to continue providing your family with clean, quality water this year. To maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. Environmental Protection Agency/Center for Disease

Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Louisa County Water Authority works to provide top quality water to every tap a round the clock. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Este informe contiene informacion muy importante sobre la calidad de su agua potable. Por favor lea este informe o comuniquese con alguien que pueda traducir la informacion.